

Air Quality Advisory Committee

September 14, 2022

Agenda

1. Welcome/Introductions
2. Recap of Previous Meeting
3. Community Opens
4. AQAC Opens
5. Good Neighbor Agreement Items Update
6. Agenda for Next Meeting
7. Public Comments/Questions

GNA-Specified Agenda Items

- Intel to report to the AQAC at its quarterly meetings on:
 - Stack testing completed since the last AQAC meeting; any stack testing planned before next AQAC meeting
 - Annual or semiannual reports submitted by Intel to DEQ pursuant to Intel's air permit
 - Any requests to DEQ for authority to modify emission factors or emission sources that were submitted since the last AQAC meeting or that Intel anticipates will be submitted prior to the next AQAC meeting
 - Update on the implementation of the measures identified on Attachment A and any measures raised in prior AQAC meetings that require further action or consideration
 - Any excess emissions and upsets reported to the Department during the most recent calendar quarter

Stack Testing Overview

- Why does Intel perform stack testing?
 - Determination of compliance with Best Available Control Technology (BACT) emission limits
 - Determination of Rotary Concentrator Thermal Oxidizer (RCTO) control efficiencies
 - Development of emission calculations for fluorides and hydrogen fluoride
 - Good Neighbor Agreement Attachment B requirements
- Stack testing plans are reviewed and approved by Oregon DEQ and utilizes standard EPA and/or DEQ test methods
- Stack testing performed by a 3rd party stack testing firm

2022 Stack Testing Update

- Complete
 - Boiler stack testing to update emission factors
 - Final report submitted to DEQ in May
- Q3/Q4
 - D1X MOD3 – Initial testing of new scrubber systems
 - D1X MOD1 and MOD2 – Re-occurring testing for existing scrubber systems
 - D1X MOD1 and MOD2 – Initial and re-occurring testing for 8 VOC abatement units (RCTOs)

Continuous Emissions Monitoring System Overview

- Rotor Concentrator Thermal Oxidizer (RCTO)
 - Used to control emissions of VOCs
 - Method of control: Thermal oxidation (combustion)
 - Temperature = Key operating parameter
 - Measurement via thermocouple
 - Minimum temperature established during stack testing
 - Temperature measurements are reviewed on an ongoing basis
 - Alarms are also set to alert when measured value outside the acceptable range
 - Alarms are indication of off-spec operation, not an indication of excess emissions or bypass

Continuous Emissions Monitoring System Overview

- Wet Scrubbers
 - Used to control emissions of acid gases, primarily Fluorides, HF, and HCl
 - Method of control: pH adjusted water absorption
 - Water flow rate and pH = Key operating parameters
 - Measurements via pH probe and flow meter
 - Minimum pH and flow established during stack testing
 - Measurements are reviewed on an ongoing basis
 - Alarms are also set to alert when measured value outside the acceptable range
 - Alarms are indication of off-spec operation, not an indication of excess emissions or bypass


Continuous Emissions Monitoring Report

– Q2 2022

Attachment C

Source	Frequency	Parameter	Equipment	Q2, 2022 Report
Rotary Concentrator Thermal Oxidizers (RCTO)	Continuous	Temperature	Thermocouple	No events
Acid Gas Scrubbers	Continuous	Flow	Flow Meter	No events
		pH	pH probe	2 events
Emergency Generators/Fire Pumps	When used	Hours of operation including time of engine start, time of engine stop and reason for operating		0 events

Continuous Emissions Monitoring Report



- Normal hourly operations for Q2 2022 is over 99.99%
 - Off-spec operation is not an indication of excess emissions and was limited to <0.01% of the hours for Q2 2022
- Blue bars indicate the number of alarms per quarter
- Red bars indicate the number of hours outside of normal operation per quarter

DEQ Submittals since May AQAC Meeting

- RCTO NOx abatement Notice of Construct submitted July 26, 2022
- D1X EXVO1 Bypass notification submitted July 8, 2022
- RS6 EGEN Automatic transfer switch malfunction following a PGE outage deviation report submitted July 27, 2022
- Q3 NOx and CO emission factor update submitted August 9, 2022
- 2022 Source test plan submitted August 18, 2022
 - Approved by DEQ on September 6, 2022

Planned Upcoming DEQ Submittals

- Submittals likely later in Q4
 - Q4 NO_x and CO emission factor update

Agenda for Q4

November 9 at 5:00 PM

- AQAC members to have input into the next agenda for each AQAC meeting
 - Standing agenda items
 - DEQ Submittals
 - Stack Testing Update
 - Project Update
 - Other?

Public Comments/Questions

BACKUP

Attachment A

Emission Reduction Project	Target Date	Status / Method of Confirmation
Advocate to contractors working at the Facility to use newer onroad and nonroad diesel engines	2 nd quarter 2016	Ongoing collaboration with suppliers to encourage reductions
Evaluate ways to reduce (if possible) diesel particulate matter emissions either with onsite or offsite projects	3 rd quarter 2016	Reported out during Q3, 2016 AQAC quarterly meeting
Decommission four Fab 5 boilers	3 rd quarter 2016	Completed
Assess feasibility of reducing waste tank emissions	4 th quarter 2016	Completed
Retrofit RCTOs to optimize natural gas usage	2 nd quarter 2017	Completed
Boiler replacement with ultra low-NOx burner boilers at RA2 and RP1	3 rd quarter 2017	Project completed. Report out during Q3, 2017 AQAC meeting
Compare actual emissions inventory in 2020 to inventory used in HRA	2 nd quarter 2021	Completed. Reported to AQAC at quarterly meeting